

Table of variables ModBus

REGISTERS	Address ModBus	Occup.	Variable name	Description	UoM	Access	Data type
INPUT	4	<u>2</u>	MainPrb	<u>Main probe reading</u>		<u>R</u>	Floating point
INPUT	6	<u>2</u>	LimitPrb	<u>Limit probe reading</u>		<u>R</u>	Floating point
INPUT	8	<u>2</u>	PreheatPrb	<u>Water preheating probe reading</u>	[°C]/[°F]	<u>R</u>	Floating point
INPUT	10	1	Conductivity	Inlet water conductivity reading	[uS/cm]	R	Unsigned